

RFB TO-24-06
Back-Up Generator at Quincy Street Station
Questions and Answers #1
April 10, 2024

Q1. What will be the allowable downtime for Topeka Metro's building when switching over the new service?

A1. 30 minutes.

Q2. Will a generator need to be provided by us to keep this building up and running during construction?

A2. Yes, if downtime exceeds 30 minutes.