



Addendum #1
February 9, 2017

Request for Bids
QSS Boiler Replacement

1. Three (3) Lochinvar Knight XL KBN801 boilers are an approved alternate installation.
2. The owner's controls vendor for coordination of the controls installation is ACS Controls, Steve 913-915-5773. Contractor shall include this controls price in their bid.
3. Weight of the existing boilers is approximately 2,500 lbs. empty each. Weight of the two (2) new boilers scheduled is approximately 850 lbs. empty each.

End of Addendum #1.