

RFB TO-21-08
Back-Up Generator at Ryan Administration Building
Questions and Answers #1
March 17, 2021

Q1. The drawing shows 120/240 volts, 3 phase, while the specs show 240 volts wye connected single phase. If it is wye connected then the voltage would 120/208 volts. Which one of the three options is correct?:

1. 120/240 volts, 3 phase, delta connected
2. 120/240 volts, 1 phase
3. 120/208 volts, 3 phase, wye connected

A1. Option 1, 120/240 volts, 3 phase, delta connected is the correct option.