

RFB TO-22-06
QSS HVAC Maintenance
Questions and Answers #1
September 10, 2021

Q1. Would you like for the contractor to change out belts annually on the AHU's and Fans or just check condition and change as needed with the parts allowance?

A1. Yes, change out belts annually.

Q2. Would you like for the contractor to change out the condensate neutralizer kit on the Laars Boilers annually?

A2. Yes.